

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/15/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155656		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 01/11/2013	
NAME OF PROVIDER OR SUPPLIER CANTERBURY NURSING AND REHABILITATION CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 2827 NORTHGATE BLVD FORT WAYNE, IN 46835			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code and Environmental Preoccupancy Survey for the conversion of 30 residential beds in rooms 520 to 547, 550 and 551 to Title 18 SNF beds was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 01/11/13</p> <p>Facility Number: 000275 Provider Number: 155656 AIM Number: 100290930</p> <p>Surveyor: Amy Kelley, Life Safety Code Specialist</p> <p>At this Life Safety Code and Environmental Preoccupancy survey, Canterbury Nursing and Rehabilitation Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety From Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) Chapter 19, Existing Health Care Occupancies, and with 410 IAC 16,2-3,1-19, Environment and Physical Standards of the Indiana Health Facilities Rules for Comprehensive care facilities for the conversion of the 30 beds in rooms 520 to 547, 550 and 551.</p> <p>This one story facility with a two story section was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and battery operated smoke detectors in the resident rooms. The facility has a capacity of 120 and had a census of</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/15/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155656		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 01/11/2013	
NAME OF PROVIDER OR SUPPLIER CANTERBURY NURSING AND REHABILITATION CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 2827 NORTHGATE BLVD FORT WAYNE, IN 46835			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>Continued From page 1 102 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. The facility had a detached garage providing facility services including the emergency generator room, storage of the mower, maintenance equipment and supplies that was not sprinklered.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 01/14/13.</p>			K 000			